

CERTIFICATE OF CONSTANCY OF PERFORMANCE

0809 - CPR - 1149

In compliance with *Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011* (the Construction Products Regulation or CPR), this certificate applies to the construction product

Sewatek penetration seal

which consist of a penetration pipe made of NBR cellular rubber surrounded by PVC pipe, intended to be used to maintain fire resistance of rigid concrete wall and roof/floor constructions or standardized flexible wall, having fire resistance of EI 15 - EI 120 in end uses and with the provisions presented in the ETA;

placed on the market under the name or trade mark of

Sewatek Oy

Sepäntie 4
FI-07230 Askola, Finland

and produced in the manufacturing plant

Sewatek Oy

Sewatek Oy
FI-07230 Askola, Finland.

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in the

ETA 12/0045

issued on 18/03/2020

and

EAD 350454-00-1104

edition September 2017

under system 1 for the performance set out in the ETA are applied and that the factory production control conducted by the manufacturer is assessed to ensure the

constancy of performance of the construction product.

This certificate was first issued on August 24, 2015 and will remain valid as long as neither the ETA, the EAD, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body. The validity of the certificate may be confirmed at the web address www.sertifikaattihaku.fi.

Espoo March 31, 2020

Tiina Ala-Outinen
Manager, Certification and Inspection

Heli Välimäki
Senior Expert